

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 297

Dated: 4/5/26.

It is certified that an inspection team headed by

Ms. PRIYANSHI PATEL (Name of Officers with designation)

from NAGAR NIGAM BHOPAL. PHED

inspected the EXCELLENCE PUBLIC SCHOOL, BARMUHALIYA EXT. LAHARPUR, BHOPAL.

(Name & Address of the school) on 2/5/26 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. 296.

dated 3/5/26 of WATER TESTING LAB, SM40 (PHED Lab)

certified that the NAGAR NIGAM BHOPAL.

EXCELLENCE PUBLIC SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 4/5/27.

Signature with Seal:

Name


Designation

Name & Address of the Office / Department : NAGAR NIGAM

BHOPAL.

To EXCELLENCE PUBLIC SCHOOL,
BARMUHALIYA EXT. LAHARPUR, BHOPAL
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



ULR No.

Nature of Sample: WATER SAMPLE	Format Number: WTL/NNBPL/4.1		Format Issue Date- 22.08.2025	
Sender's Name and Address: Excellence Public School, Laharpur Bhopal.	Sender's Letter No.	-	Sender's Letter Date	-
	Sample collection date	02.05.2026	WTL Receipt Date	02.05.2026
	Date of Analysis Started	02.05.2026	Date of analysis completed	03.05.2026
	Environmental Conditions at the time of Testing : Temperature - 25.°C Humidity-56			

Sample Details		
S.No.	Particular Of Sample	WTL Ref No
1.	Excellence Public School, Bagmugaliya Extension, Laharpur Bhopal. (Water Sample)	58
2.		
3.		

Sub Group : Drinking water

			Result		Results		
Sr. No.	Characteristics/Unit	Test Methods	IS-10500:2012 REAFFIRMED IN 2023		1	2	3
			Desirable Limit	Permissible Limit			
(1)	(2)	(3)	(4)	(5)			
1	Colour in CU	IS 3025 Part 4: 2021	5	15	BDL		
2	Taste	IS 3025 Part 8: 2023	Agreeable	Unagreeable	Agr.		
3	Odour	IS 3025 Part 5: 2018	Agreeable	Unagreeable	Agr.		
4	pH Value at 25°C	IS 3025 Part 11: 2022	6.5 to 8.5	6.5 to 8.5	6.68		
5	Chloride as Cl mg/l	IS 3025 Part 32: 2019	250	1000	35		
6	Total Alkalinity as CaCO3 mg/l	IS 3025 Part 23: 2023	200	600	16		
7	Calcium as Ca++ mg/l	IS 3025 Part 40: 2024	75	200	12.8		
8	Magnesium as Mg++ mg/l	APHA 24TH edition, 3500 Mg : 2023	30	100	5.76		
9	Turbidity in NTU	IS 3025 Part 10: 2023	1	5	BDL		
10	Total Hardness as CaCO3 mg/l	IS 3025 Part 21: 2023	200	600	56		
11	TDS mg/l	IS 3025 Part 16: 2023	500	2000	85		

* End of the report *

1. The results refer only to tested samples and parameters tested
2. Samples will be stored for a period of 5 days from the date of issue of report.
3. This lab does not hold any responsibility for variation in results for samples kept or held for want of identification
4. This report should not be produced partly or full without approval of signatory authority for legal purposes
5. "BCL" stands for Below Detectable Limit

Water Testing Laboratory 5 MC
Nagar Nigam, Arera Hills, Bhopal

Issue No. 296 /WTL/NN/BPL /2026 Issue Date 3/5/26



Water Testing Laboratory 5 MGD
Nagar Nigam, Arera Hills, Bhopal

TEST REPORT

Nature of Sample : WATER SAMPLE	Format Number: WTL/NN/BPL/4.1		Format Issue Date- 22.08.2025	
Sender's Name and Address: Excellence Public School, Laharpur Bhopal.	Sender's Letter No.	-	Sender's Letter Date	-
	Sample collection date	02.05.2026	WTL Receipt Date	02.05.2026
	Date of Analysis Started	02.05.2026	Date of analysis completed	03.05.2026
	Environmental Conditions at the time of Testing : Temperature - 25.°C Humidity-56			

S.No.	Particular Of Sample	WTL Ref No
1.	Excellence Public School, Bagmugaliya Extension, Laharpur Bhopal. (Water Sample)	58
2.		
3.		

Sr. No.	Characteristics/Unit	Test Methods	IS-10500:2012 REAFFIRMED IN 2023		Results		
			Desirable Limit	Permissible Limit	1	2	3
(1)	(2)	(3)	(4)	(5)			
1	Free Residual Chlorine in ppm	IS 3025 Part 26	0.2	1	NIL		
2	Total coliform per 100 ml	APHA 24th edition, 9211 B			NIL		
3	E coli or (TTC) per 100 ml	IS 1622	NIL for treated water and water in distribution system.		NIL		

* End of the report *-

1. The results refer only to tested samples and parameters tested
2. Samples will be stored for a period of 5 days from the date of issue of report.
3. This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification
4. This report should not be produced partly or full without approval of signatory authority for legal purposes
5. "BDL" stands for Below Detectable Limit.

Incharge

Water Testing Laboratory 5 MGD
Nagar Nigam, Arera Hills, Bhopal

Issue No. 296 /WTL/NN/BPL /2026 Issue Date 13/5/26